


General Notes

1. In order for a new or revamp to a service will be scheduled for work the following is required to be completed
 - a. Site visit with engineering for location and routing.
 - b. Pay Membership and Security Deposits.
 - c. Any Aid-to-Construction is paid.
 - d. Signed and notarization of required easements.
 - e. Member mounted meter and disconnect.
2. Meter base needs to be installed so that the meter is 5' to 5 ½'.
3. The base mounted at minimum of 3' from windows, doors, porches, balconies, ladders, stairs, fire escapes, or other locations accessible to pedestrian traffic.
4. The trenching/digging of conductor to service requires area to be at or close to final grade.
5. Cooperative shall trench/dig for the service wire to base. The Cooperative will refill the trench with backfill. The member will be responsible for compacting trench and repairing sidewalks, driveways, etc.
6. Meter base needs to meet NEC code or regional code.

Call JULIE-One Call before you dig [800-892-0123](tel:800-892-0123)



Underground Service Installation "House"
Single Phase 120/240V, Three Wire, 320 AMP