

\*\* OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. \*\*

**NOVEMBER 2019**

11/01/19 – 5:19 AM

Nutwood – wind, tree thru line, off 2 ½ hrs.

11/03/19 – 9:27 AM

Womac – bad connection in meter base, off 2 ½ hrs.

11/05/19 – 8:11 PM

Womac – bad transformer, off 1hr.

11/08/19 –

11:18 AM - Butler – frayed strands in phase got into neutral had breaker locked out, off 1 ½ hrs.

1:02 PM - Taylor Springs – someone bumped pole slapping phases together, off 1hr 20mins.

11/09/19 – 3:35 PM

Nutwood – trees in line, off 1 hr.

11/10/19 - 12:57 PM

Taylor Springs – tripped breaker, unknown cause, off 2 ½ hrs.

11/11/19 – 1:43 PM

Jerseyville – wind, trees thru line, off 4hrs. 11mins.

11/13/19 – 8:10 AM

Rinaker – burned arrestor elbow inside transformer & blown fuses underground, off 1 ½ hrs.

11/19/19 – 8:56 AM

Jerseyville – tractor hit pole, lines down, off 3hrs.

11/21/19 –

9:00 AM - Rinaker – planned outage, maintenance c/o (2) 3-phase poles, off 1 ½ hours.

9:54 AM - Jerseyville – frayed/broken strands, off 2hrs.

11/23/19 – 3:10 PM

Staunton – phase & neutral wrapped around each other, off 3hrs.

11/24/19 – 2:37 PM

Womac – broken stinger wire, off 1 ½ hrs.

11/26/19 –

5:23 PM - Staunton – rain, trees in line, broken pole, off 3hrs.

7:30 PM - Butler – rain/wind – trees in line, off 3hrs. 20mins.

11/27/19 –

2:06 AM - Nutwood – high winds, trees in line/lines down, off 4hrs.

5:08 AM - Brighton – high winds, broken stinger wire on transformer, pole down.

5:29 AM - Butler – high winds, #897 & #892 broken pole, trees in line, Off 4hrs.

6:05 AM - Nutwood – high winds, tree limb on transformer, blown line fuse, off 2 ½ hrs.

6:14 AM - Bunker Hill - high winds, #257 broken pole, off 4hrs.

10:02 AM - Rinaker – high winds, #865 tripped breaker, trees in line, off 1hr.

10:04 AM - Staunton – high wind, trees slapped lines together, off 1 ½ hrs.