

\*\* OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. \*\*

## **JUNE 2019**

### **06/05/2019 -4:00 PM**

Palmyra – Ameren transmission, c/o pole, off 1 1/2hrs

### **06/06/2019 – 6:35 AM**

Newbern – trees, off 2 ½ hrs

### **06/07/2019 – 11:51 AM**

Jerseyville – maintenance, c/o

### **06/10/2019 – 12:54 PM**

Newbern – tree thru line, OCR #744 is out, creek is out of banks, impassible due to waters, brought boat in, off 4hrs.

### **06/14/2019**

1:14 PM - Womac – lightning, refused line, off 2 ½ hrs.

10:24 PM - Witt – lightning/rain, refused line, off 1 ½ hrs

11:00 PM - Staunton – lightning/rain, refused line, off 2hrs.

### **06/15/2019**

5:50 AM - Palmyra – storm/lightning, broken poles off 4 ½ hrs

7:49 AM - Womac – pole struck by lightning, off 1hr

2:14 PM - Brighton – storm/ lightning, trees thru line, off 5hrs

11:42 PM - Staunton – storm/lightning, pole top on fire, off 2hrs

### **06/16/2019**

1:11 AM - Palmyra – storm/lighting, tree thru line, off 3hrs

1:20 AM - Taylor Springs – storm/lightning, car accident, broken pole, off 1hr

### **06/17/2019**

1:54 PM - Staunton – trees rubbing triplex in private, burned line down, off 3hrs

7:00 pm - Womac – bad underground. Off 2hrs.

### **06/19/2019 – 2:39 PM**

Witt – lightning struck pole, phase laying on top of pole burning, off 1 ½hrs

### **06/21/2019**

12:11 PM - Rinaker – major storm, phase out at substation, off 1 ½hrs

1:11 PM - Staunton – major storm, trees in line, off 2hrs

1:12 PM - Womac – lightning, high voltage transformer, off 3hrs

### **06/22/2019**

Newbern – trees, off 1 ½ hrs.

**06/28/2019** – 2:46 PM

Brighton – lightning, transformer – taking planned outage to replace all insulators, cut-outs, & checking all other connections, off 1hr.