

**** OCR, Feeders and Subs are included. Fuses, transformers and individuals are not. ****

JULY 2020

07/01/2020 –

4:48AM - Nutwood – storm , trees thru line, off 4hrs.

12:19PM - Butler – storm, trees in line, off 3 ½ hrs.

6:05PM - Hornsby – lightning, blown underground transformer fuse, off 1hr 10mins

07/05/2020 – 1:14PM

Bunker Hill – trees in line, off 1 ½ hrs

07/08/2020 – 1:10PM

Bunker Hill – linemen put 2 spans line back up, off ½ hr.

07/15/2020 –

4:11PM - Jerseyville – lightning arrester, substation, off 2hrs.

5:06PM - Staunton – storm, lightning; tree took out 2 spans 3-pase primary line, off 4hrs

5:08PM - Taylor Springs – storm, lightning; trees took out lines in private, off 8hrs.

5:13PM - Staunton – storm, lightning; tree down, lines down, off 5hrs

5:21PM - Butler – storm, lightning, tree thru primary line, tripped OCR, off 3 ½ hrs

7/21/2020 – 7:32PM

Nutwood – rain, lightning, wind – trees thru primary line, off 4 ½ hrs.

7/22/2020 – 8:30AM

Witt – several insulators damaged in storm, off 1hr

07/23/2020 –

9:30AM - Rinaker – c/o pole from earlier vehicle accident, off 1hr.

4:10PM - Nutwood – trees in line, off 1 1/2hr

07/27/2020-4:09PM

Butler – rain, trees in line, off 1hr

07/30/2020 – 10:03AM

Rinaker – tree on line, rain, off 1 ½ hrs.